🕅 Dalmacija Klima d.o.o.



- 14.200 m³/h of the exhaust air at thetemperature 110°C was spewed out into the atmosphere during operation of the dryer by using centrifugal extractor fans,
- The required amount of fresh air in the area of non-woven textile: 71 000 m³/h
- Estimated average temperature, in winter time, at a height of 1 m from the ground is 12 ° C, while the estimated temperature under the roof at the same time was about 25 °C.

🕅 Dalmacija Klima d.o.o.



DRYER

- By installing units for use of waste heat on the roof of the hall, the air from the furnace and air under the roof were directed to a heat exchanger which recovers heat from a polluted air and heats the outdoor pure cold air. A preheated air at the temperature of approximately 8 ° C, prepared in such way, is additionally heated by a compressor unit up to 11-12°C and injected into the hall.
- The energy consumption for heating the hall in winter time is reduced by 75% compared to the previous condition.
- Based on the Project of use of waste heat was achieved also a clean air in the premises of the hall in winter time.